



CITY OF MADISON FIRE DEPARTMENT

Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295

Phone: 608-266-4484 ♦ FAX: 608-267-1153

International Fire Code/2000

Chapter 3 GENERAL PRECAUTIONS AGAINST FIRE SECTION 308 OPEN BURNING

308.3.1 Open-flame cooking devices.

Charcoal burners and other open-flame cooking devices shall not be operated on combustible balconies or within 10 feet (3048 mm) of combustible construction.

Exceptions:

1. One- and two-family dwellings.
2. Where buildings and decks are protected by an automatic sprinkler system.

308.3.1.1 Liquefied-petroleum-gas-fueled cooking devices.

LP-gas burners having a LP-gas container with a water capacity greater than 2.5 pounds (1.14 kg) [nominal 1 pound (0.454 kg) LP-gas capacity] shall not be located on combustible balconies or within 10 feet (3048 mm) of combustible construction.

Exception:

One- and two-family dwellings.

MGO 34.01 (14) (a) adopts the International Fire Code as of July 8, 2002.