



City of Madison Fire Department

Installation Table

Currently Installed Alarms	New Requirement
110-volt older than 10 years	110-volt with battery back-up
110-volt interconnected older than 10 years	110-volt with battery back-up and interconnected
9-volt	10-year lithium (tamper-resistant or sealed) battery or 110-volt with battery back-up
Bedroom or hallway	Both sides of bedroom doors Hallway must be within 6 feet of the door
	All additional alarms above what is currently installed must be 110- volt with battery back-up or 10-year lithium battery

Battery back-up may be standard, rechargeable or lithium battery

Dates: rental properties – August 15, 2009

owner-occupied single-family – August 15, 2010