



Legend

☉ Denotes Boring Location

Notes

1. Soil Borings performed by America's Drilling Co. in September 2023 (B1, B2, B5 and B6) or Badger State Drilling in October 2016 (B3, B4 and B4-X)
2. Boring locations are approximate

Scale: Reduced

| | |
|----------------|-----------|
| Date: | 9/2023 |
| Job No. | C23051-13 |



Soil Boring Location Map
East Doty and East Wilson Streets
Madison, WI



LOG OF TEST BORING

Project East Doty and East Wilson Streets
 Doty: 90'NE of MLK Jr. Blvd., 15'SE of Centerline
 Location Madison, Wisconsin

Boring No. 1
 Surface Elevation (ft) 912±
 Job No. C23051-13
 Sheet 1 of 1

2921 Perry Street, Madison, WI 53713 (608) 288-4100, FAX (608) 288-7887

| SAMPLE | | | | | VISUAL CLASSIFICATION and Remarks | SOIL PROPERTIES | | | | |
|--------|------|--------------|-------|----|--------------------------------------|------------------------------------------------------------------------------------------------------------|---------------------|---|----|----|
| No. | TYPE | Rec (in.) | Moist | N | | Depth (ft) | qu (qa) (tsf) | W | LL | PL |
| | | | | | L | 8 in. Asphalt Pavement/3 in. Base Course | | | | |
| 1 | | 8 | M | 6 | L | Stiff, Brown Lean CLAY (CL) | | | | |
| 2 | | 8 | M | 6 | L | (1.25) | | | | |
| | | | | | 5 | Loose to Dense, Brown Fine to Medium SAND, Some Silt and Gravel, Scattered Cobbles and Boulders (SM) | | | | |
| 3 | | 12 | M | 9 | L | | | | | |
| 4 | | 12 | M | 27 | L | (1.25) | | | | |
| | | | | | 10 | | | | | |
| 5 | | 14 | M | 45 | L | End of Boring at 15 ft Backfilled with Bentonite Chips and Asphalt Patch | | | | |
| | | | | | 15 | | | | | |
| | | | | | 20 | | | | | |

WATER LEVEL OBSERVATIONS

GENERAL NOTES

While Drilling NW Upon Completion of Drilling _____
 Time After Drilling _____
 Depth to Water _____
 Depth to Cave in _____

Start 9/12/23 End 9/12/23
 Driller ADC Chief KD Rig CME-55
 Logger PD Editor ESF
 Drill Method 2.25" HSA; Autohammer

The stratification lines represent the approximate boundary between soil types and the transition may be gradual.



LOG OF TEST BORING

Project East Doty and East Wilson Streets
 Doty: 135'NE of Pinckney, 20'SE of Centerline
 Location Madison, Wisconsin

Boring No. 2
 Surface Elevation (ft) 905±
 Job No. C23051-13
 Sheet 1 of 1

2921 Perry Street, Madison, WI 53713 (608) 288-4100, FAX (608) 288-7887

| SAMPLE | | | | | VISUAL CLASSIFICATION and Remarks | SOIL PROPERTIES | | | | |
|--------|--------------|-------|----|---------------|-------------------------------------------------------------------------------------------------------------|---------------------------------|---|----|----|-----|
| No. | Rec (in.) | Moist | N | Depth (ft) | | q _u (qa) (tsf) | W | LL | PL | LOI |
| | | | | 0 | 6 in. Asphalt Pavement/6 in. Recycled Asphalt | | | | | |
| 1 | 6 | M | 7 | 7 | Stiff to Very Stiff, Brown Lean CLAY (CL) | (1.25) | | | | |
| | | | | 10 | | | | | | |
| 2 | 12 | M | 10 | 10 | | (2.25) | | | | |
| | | | | 14 | | | | | | |
| 3 | 8 | M | 14 | 14 | Medium Dense to Dense, Brown Fine to Medium SAND, Some Silt and Gravel, Scattered Cobbles and Boulders (SM) | | | | | |
| | | | | 24 | | | | | | |
| 4 | 8 | M | 24 | 24 | | | | | | |
| | | | | 37 | | | | | | |
| 5 | 14 | M | 37 | 37 | End of Boring at 15 ft | | | | | |
| | | | | 15 | Backfilled with Bentonite Chips and Asphalt Patch | | | | | |
| | | | | 20 | | | | | | |

WATER LEVEL OBSERVATIONS

GENERAL NOTES

While Drilling NW Upon Completion of Drilling _____
 Time After Drilling _____
 Depth to Water _____
 Depth to Cave in _____

Start 9/12/23 End 9/12/23
 Driller ADC Chief KD Rig CME-55
 Logger PD Editor ESF
 Drill Method 2.25" HSA; Autohammer

The stratification lines represent the approximate boundary between soil types and the transition may be gradual.



LOG OF TEST BORING

Project East Doty and East Wilson Streets
Wilson: 180'SW of Pinckney, 15'SE of Centerline
 Location Madison, Wisconsin

Boring No. 3
 Surface Elevation (ft) 901±
 Job No. C23051-13
 Sheet 1 of 1

2921 Perry Street, Madison, WI 53713 (608) 288-4100, FAX (608) 288-7887

| SAMPLE | | | | | VISUAL CLASSIFICATION and Remarks | SOIL PROPERTIES | | | | |
|---------------------------------------------------|--------------|-------|----|---------------|------------------------------------------------------------------------------------------------------------------|---------------------|---|----|----|-----|
| No. | Rec (in.) | Moist | N | Depth (ft) | | qu (qa) (tsf) | W | LL | PL | LOI |
| | | | | 0 | 6 in. Asphalt Pavement/5 in. Base Course | | | | | |
| IAS | 0 | M | 9 | 9 | Medium-Stiff to Stiff, Brown Lean CLAY (CL) | (1.0) | | | | |
| 2 | 15 | M | 20 | 20 | Medium Dense to Very Dense, Brown Fine to Medium SAND, Some Silt and Gravel, Scattered Cobbles and Boulders (SM) | | | | | |
| 3 | 10 | M | 33 | 33 | | | | | | |
| 4 | 20 | M | 24 | 24 | | | | | | |
| 5 | 17 | M | 58 | 58 | | | | | | |
| End of Boring at 15 ft | | | | | | | | | | |
| Backfilled with Bentonite Chips and Asphalt Patch | | | | | | | | | | |

WATER LEVEL OBSERVATIONS

GENERAL NOTES

While Drilling NW Upon Completion of Drilling _____
 Time After Drilling _____
 Depth to Water _____
 Depth to Cave in _____

Start 10/4/16 End 10/4/16
 Driller BSD Chief DB Rig CME-55
 Logger FD Editor ESF
 Drill Method 2 1/4" HSA; Autohammer

The stratification lines represent the approximate boundary between soil types and the transition may be gradual.



LOG OF TEST BORING

Project East Doty and East Wilson Streets
Wilson: 350'SW of Butler, 23'SE of Centerline
 Location Madison, Wisconsin

Boring No. 4
 Surface Elevation (ft) 889±
 Job No. C23051-13
 Sheet 1 of 1

2921 Perry Street, Madison, WI 53713 (608) 288-4100, FAX (608) 288-7887

| SAMPLE | | | | | VISUAL CLASSIFICATION and Remarks | SOIL PROPERTIES | | | | |
|--------|--------------|-------|----|---------------|------------------------------------------------------------------------------------------------------------------------------------|---------------------|---|----|----|-----|
| No. | Rec (in.) | Moist | N | Depth (ft) | | qu (qa) (tsf) | W | LL | PL | LOI |
| | | | | 5 | Blind Drilled to 6 ft FILL: Reddish-Brown Landscape Gravel to 0.5 ft Brown Silty Sand with Gravel and Clay to 5.5 ft | | | | | |
| 1 | 1 | M | 32 | | Medium Dense to Dense, Brown Fine to Medium SAND, Some Silt and Gravel, Scattered Cobbles and Boulders (SM) | | | | | |
| 2 | 15 | M | 28 | 10 | | | | | | |
| 3 | 18 | M | 38 | 15 | | | | | | |
| | | | | 20 | End of Boring at 15 ft Backfilled with Bentonite Chips and Landscape Gravel | | | | | |

WATER LEVEL OBSERVATIONS

GENERAL NOTES

While Drilling NW Upon Completion of Drilling _____
 Time After Drilling _____
 Depth to Water _____
 Depth to Cave in _____

Start 10/4/16 End 10/4/16
 Driller BSD Chief DB Rig CME-55
 Logger FD Editor ESF
 Drill Method 2 1/4" HSA; Autohammer

The stratification lines represent the approximate boundary between soil types and the transition may be gradual.



LOG OF TEST BORING

Project East Doty and East Wilson Streets
Wilson: 350'SW of Butler, 15'SE of Centerline
 Location Madison, Wisconsin

Boring No. 4X
 Surface Elevation (ft) 889±
 Job No. C23051-13
 Sheet 1 of 1

2921 Porry Street, Madison, WI 53713 (608) 288-4100, FAX (608) 288-7887

| SAMPLE | | | | | VISUAL CLASSIFICATION and Remarks | SOIL PROPERTIES | | | | |
|--------|----------------------|-------|---|---------------|--------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---|----|----|-----|
| No. | TYPE Rec (in.) | Moist | N | Depth (ft) | | qu (qa) (tsf) | W | LL | PL | LOI |
| | | | | 0 | X | 6 in. Asphalt Pavement/4 in. Base Course | | | | |
| 1 | 12 | M | | 23 | X | FILL: Brown Fine Sand to 3.5 ft | | | | |
| | | | | 3.5 | X | Pink Insulation Atop Concrete to 3.7 ft | | | | |
| 2 | 1 | M | | 50/2" | X | End of Boring at 3.7 ft Due to Spoon Refusal on <i>Unmarked</i> WI DOA Steam Tunnel. Boring renamed, backfilled with soil cuttings and patched with asphalt. B4 performed approximately 8 ft to the SE and successfully advanced to the requested depth. | | | | |
| | | | | 5 | | | | | | |
| | | | | 10 | | | | | | |
| | | | | 15 | | | | | | |
| | | | | 20 | | | | | | |

WATER LEVEL OBSERVATIONS

GENERAL NOTES

While Drilling NW Upon Completion of Drilling _____
 Time After Drilling _____
 Depth to Water _____
 Depth to Cave in _____

Start 10/4/16 End 10/4/16
 Driller BSD Chief DB Rig CME-55
 Logger FD Editor ESF
 Drill Method 2 1/4" HSA; Autohammer

The stratification lines represent the approximate boundary between soil types and the transition may be gradual.



LOG OF TEST BORING

Project East Doty and East Wilson Streets
Wilson: 105'NE of Butler, 3'NW of Centerline
 Location Madison, Wisconsin

Boring No. 5
 Surface Elevation (ft) 873±
 Job No. C23051-13
 Sheet 1 of 1

2921 Perry Street, Madison, WI 53713 (608) 288-4100, FAX (608) 288-7887

| SAMPLE | | | | | VISUAL CLASSIFICATION and Remarks | SOIL PROPERTIES | | | | |
|--------|------|--------------|-------|----|--------------------------------------|-------------------------------------------------------------------------------------------------------------|---------------------|---|----|----|
| No. | TYPE | Rec (in.) | Moist | N | | Depth (ft) | qu (qa) (tsf) | W | LL | PL |
| | | | | | 5 | 5 in. Asphalt Pavement/6 in. Recycled Asphalt | | | | |
| 1 | | 10 | M | 24 | 5 | FILL: Medium Dense Brown Sand with Gravel and Silt | | | | |
| 2 | | 8 | M | 29 | 5 | | | | | |
| 3 | | 12 | M | 21 | 5 | Medium Dense to Dense, Brown Fine to Medium SAND, Some Silt and Gravel, Scattered Cobbles and Boulders (SM) | | | | |
| 4 | | 12 | M | 31 | 10 | | | | | |
| 5 | | 14 | M | 34 | 15 | | | | | |
| | | | | | 15 | End of Boring at 15 ft Backfilled with Bentonite Chips and Asphalt Patch | | | | |
| | | | | | 20 | | | | | |

WATER LEVEL OBSERVATIONS

GENERAL NOTES

While Drilling NW Upon Completion of Drilling _____
 Time After Drilling _____
 Depth to Water _____
 Depth to Cave in _____

Start 9/12/23 End 9/12/23
 Driller ADC Chief KD Rig CME-55
 Logger PD Editor ESF
 Drill Method 2.25" HSA; Autohammer

The stratification lines represent the approximate boundary between soil types and the transition may be gradual.



LOG OF TEST BORING

Project East Doty and East Wilson Streets
 Location Wilson: 50'NE of Hancock, 30'NW of Centerline
Madison, Wisconsin

Boring No. 6
 Surface Elevation (ft) 862±
 Job No. C23051-13
 Sheet 1 of 1

2921 Perry Street, Madison, WI 53713 (608) 288-4100, FAX (608) 288-7887

| SAMPLE | | | | | VISUAL CLASSIFICATION and Remarks | SOIL PROPERTIES | | | | |
|--------|------|-----------|-------|----|--------------------------------------|----------------------------------------------------------------------------------------------------|---------------|---|----|----|
| No. | TYPE | Rec (in.) | Moist | N | | Depth (ft) | qu (qa) (tsf) | W | LL | PL |
| | | | | | 1 | 1.5 in. Asphalt Pavement/6 in. Concrete Pavement/4 in. Base Course | | | | |
| 1 | | 8 | M | 9 | 1 | | | | | |
| 2 | | 10 | M | 6 | 5 | Medium Dense, Brown Fine to Medium SAND, Some Silt and Gravel, Scattered Cobbles and Boulders (SM) | | | | |
| 3 | | 12 | M | 16 | 5 | | | | | |
| 4 | | 14 | M | 20 | 10 | Medium Dense, Brown Fine to Medium SAND, Some Silt and Gravel, Scattered Cobbles and Boulders (SM) | | | | |
| 5 | | 12 | W | 20 | 10 | | | | | |
| 6 | | 12 | W | 26 | 15 | Medium Dense, Brown Fine to Medium SAND, Some Silt and Gravel, Scattered Cobbles and Boulders (SM) | | | | |
| | | | | | 15 | | | | | |
| | | | | | 20 | Backfilled with Bentonite Chips and Asphalt Patch | | | | |

WATER LEVEL OBSERVATIONS

GENERAL NOTES

While Drilling ∇ 11.0' Upon Completion of Drilling _____
 Time After Drilling _____ 15 Min.
 Depth to Water _____ ∇
 Depth to Cave in _____ 10'

Start 9/12/23 End 9/12/23
 Driller ADC Chief KD Rig CME-55
 Logger PD Editor ESF
 Drill Method 2.25" HSA; Autohammer

The stratification lines represent the approximate boundary between soil types and the transition may be gradual.

LOG OF TEST BORING
General Notes

DESCRIPTIVE SOIL CLASSIFICATION

Grain Size Terminology

| Soil Fraction | Particle Size | U.S. Standard Sieve Size |
|---------------------|-----------------------------|--------------------------|
| Boulders | Larger than 12" | Larger than 12" |
| Cobbles | 3" to 12" | 3" to 12" |
| Gravel: Coarse..... | ¾" to 3" | ¾" to 3" |
| Fine | 4.76 mm to ¾"..... | #4 to ¾" |
| Sand: Coarse..... | 2.00 mm to 4.76 mm..... | #10 to #4 |
| Medium | 0.42 to mm to 2.00 mm | #40 to #10 |
| Fine | 0.074 mm to 0.42 mm..... | #200 to #40 |
| Silt..... | 0.005 mm to 0.074 mm..... | Smaller than #200 |
| Clay | Smaller than 0.005 mm..... | Smaller than #200 |

Plasticity characteristics differentiate between silt and clay.

General Terminology

- Physical Characteristics
- Color, moisture, grain shape, fineness, etc.
- Major Constituents
- Clay, silt, sand, gravel
- Structure
- Laminated, varved, fibrous, stratified, cemented, fissured, etc.
- Geologic Origin
- Glacial, alluvial, eolian, residual, etc.

Relative Density

| Term | "N" Value |
|-------------------|-----------|
| Very Loose..... | 0 - 4 |
| Loose..... | 4 - 10 |
| Medium Dense..... | 10 - 30 |
| Dense..... | 30 - 50 |
| Very Dense..... | Over 50 |

Relative Proportions Of Cohesionless Soils

| Proportional Term | Defining Range by Percentage of Weight |
|-------------------|----------------------------------------|
| Trace..... | 0% - 5% |
| Little..... | 5% - 12% |
| Some..... | 12% - 35% |
| And | 35% - 50% |

Consistency

| Term | q _u -tons/sq. ft |
|-----------------|-----------------------------|
| Very Soft..... | 0.0 to 0.25 |
| Soft..... | 0.25 to 0.50 |
| Medium..... | 0.50 to 1.0 |
| Stiff..... | 1.0 to 2.0 |
| Very Stiff..... | 2.0 to 4.0 |
| Hard..... | Over 4.0 |

Organic Content by Combustion Method

| Soil Description | Loss on Ignition |
|---------------------------|------------------|
| Non Organic..... | Less than 4% |
| Organic Silt/Clay..... | 4 - 12% |
| Sedimentary Peat..... | 12% - 50% |
| Fibrous and Woody Peat... | More than 50% |

Plasticity

| Term | Plastic Index |
|----------------------|---------------|
| None to Slight..... | 0 - 4 |
| Slight..... | 5 - 7 |
| Medium..... | 8 - 22 |
| High to Very High .. | Over 22 |

The penetration resistance, N, is the summation of the number of blows required to effect two successive 6" penetrations of the 2" split-barrel sampler. The sampler is driven with a 140 lb. weight falling 30" and is seated to a depth of 6" before commencing the standard penetration test.

SYMBOLS

Drilling and Sampling

- CS – Continuous Sampling
- RC – Rock Coring: Size AW, BW, NW, 2"W
- RQD – Rock Quality Designation
- RB – Rock Bit/Roller Bit
- FT – Fish Tail
- DC – Drove Casing
- C – Casing: Size 2 ½", NW, 4", HW
- CW – Clear Water
- DM – Drilling Mud
- HSA – Hollow Stem Auger
- FA – Flight Auger
- HA – Hand Auger
- COA – Clean-Out Auger
- SS – 2" Dia. Split-Barrel Sample
- 2ST – 2" Dia. Thin-Walled Tube Sample
- 3ST – 3" Dia. Thin-Walled Tube Sample
- PT – 3" Dia. Piston Tube Sample
- AS – Auger Sample
- WS – Wash Sample
- PTS – Peat Sample
- PS – Pitcher Sample
- NR – No Recovery
- S – Sounding
- PMT – Borehole Pressuremeter Test
- VS – Vane Shear Test
- WPT – Water Pressure Test

Laboratory Tests

- q_a – Penetrometer Reading, tons/sq ft
- q_u – Unconfined Strength, tons/sq ft
- W – Moisture Content, %
- LL – Liquid Limit, %
- PL – Plastic Limit, %
- SL – Shrinkage Limit, %
- LI – Loss on Ignition
- D – Dry Unit Weight, lbs/cu ft
- pH – Measure of Soil Alkalinity or Acidity
- FS – Free Swell, %

Water Level Measurement

- ▽ - Water Level at Time Shown
- NW – No Water Encountered
- WD – While Drilling
- BCR – Before Casing Removal
- ACR – After Casing Removal
- CW – Cave and Wet
- CM – Caved and Moist

Note: Water level measurements shown on the boring logs represent conditions at the time indicated and may not reflect static levels, especially in cohesive soils.

CGC, Inc.

Madison - Milwaukee

Unified Soil Classification System

UNIFIED SOIL CLASSIFICATION AND SYMBOL CHART

COARSE-GRAINED SOILS

(more than 50% of material is larger than No. 200 sieve size)

| GRAVELS | | Clean Gravels (Less than 5% fines) | |
|---------------------------------------------------------------|------------------------------------------|------------------------------------|-----------------------------------------------------------------|
| More than 50% of coarse fraction larger than No. 4 sieve size | | GW | Well-graded gravels, gravel-sand mixtures, little or no fines |
| | | GP | Poorly-graded gravels, gravel-sand mixtures, little or no fines |
| | Gravels with fines (More than 12% fines) | | |
| | | GM | Silty gravels, gravel-sand-silt mixtures |
| | | GC | Clayey gravels, gravel-sand-clay mixtures |
| SANDS | | Clean Sands (Less than 5% fines) | |
| 50% or more of coarse fraction smaller than No. 4 sieve size | | SW | Well-graded sands, gravelly sands, little or no fines |
| | | SP | Poorly graded sands, gravelly sands, little or no fines |
| | Sands with fines (More than 12% fines) | | |
| | | SM | Silty sands, sand-silt mixtures |
| | | SC | Clayey sands, sand-clay mixtures |

FINE-GRAINED SOILS

(50% or more of material is smaller than No. 200 sieve size.)

| SILTS AND CLAYS | Liquid limit less than 50% | | ML | Inorganic silts and very fine sands, rock flour, silty or clayey fine sands or clayey silts with slight plasticity |
|----------------------|-----------------------------|----|-------------------------------------|--------------------------------------------------------------------------------------------------------------------|
| | | | CL | Inorganic clays of low to medium plasticity, gravelly clays, sandy clays, silty clays, lean clays |
| | | | OL | Organic silts and organic silty clays of low plasticity |
| SILTS AND CLAYS | Liquid limit 50% or greater | | MH | Inorganic silts, micaceous or diatomaceous fine sandy or silty soils, elastic silts |
| | | | CH | Inorganic clays of high plasticity, fat clays |
| | | | OH | Organic clays of medium to high plasticity, organic silts |
| HIGHLY ORGANIC SOILS | | PT | Peat and other highly organic soils | |

LABORATORY CLASSIFICATION CRITERIA

| | | |
|----|-----------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------|
| GW | $C_u = \frac{D_{60}}{D_{10}}$ greater than 4; $C_c = \frac{D_{30}}{D_{10} \times D_{60}}$ between 1 and 3 | |
| GP | Not meeting all gradation requirements for GW | |
| GM | Atterberg limits below "A" line or P.I. less than 4 | Above "A" line with P.I. between 4 and 7 are borderline cases requiring use of dual symbols |
| GC | Atterberg limits above "A" line or P.I. greater than 7 | |
| SW | $C_u = \frac{D_{60}}{D_{10}}$ greater than 4; $C_c = \frac{D_{30}}{D_{10} \times D_{60}}$ between 1 and 3 | |
| SP | Not meeting all gradation requirements for GW | |
| SM | Atterberg limits below "A" line or P.I. less than 4 | Limits plotting in shaded zone with P.I. between 4 and 7 are borderline cases requiring use of dual symbols |
| SC | Atterberg limits above "A" line with P.I. greater than 7 | |

Determine percentages of sand and gravel from grain-size curve. Depending on percentage of fines (fraction smaller than No. 200 sieve size), coarse-grained soils are classified as follows:

Less than 5 percent GW, GP, SW, SP
 More than 12 percent GM, GC, SM, SC
 5 to 12 percent Borderline cases requiring dual symbols

PLASTICITY CHART

