



Department of Public Works
Engineering Division
James M. Wolfe, P.E., City Engineer
City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4751
Fax: (608) 264-9275
engineering@cityofmadison.com
www.cityofmadison.com/engineering

Assistant City Engineer
Bryan Cooper, AIA
Gregory T. Fries, P.E.
Chris Petykowski, P.E.
Deputy Division Manager
Kathleen M. Cryan
Principal Engineer 2
John S. Fahrney, P.E.
Janet Schmidt, P.E.
Principal Engineer 1
Mark D. Moder, P.E.
Financial Manager
Steven B. Danner-Rivers

February 21, 2023

**NOTICE OF ADDENDUM
ADDENDUM 1
CONTRACT NO. 8875, PROJECT NO. 11063
LOWER BADGER MILL CREEK FLOOD MITIGATION**

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

PLANS:

REMOVE

Remove Sheet 2

INSERT

Insert Sheet 2

Sheet 2 is being revised to include an Earthwork Summary.

SPECIAL PROVISIONS:

ADD: BID ITEM 90019 – CONSTRUCTION SURVEYING

A. DESCRIPTION

The Contractor shall be responsible for all surveying and staking required for layout, construction and accurate completion of the project in accordance with the plans or any field changes directed by the Engineer. This includes staking all objects shown in the plans, limits, lines, contours, bid items, additional control, and grades required for construction of the project. An AutoCAD (.dwg) file and digital terrain model file will be provided by the City upon request. The Contractor shall be responsible for configuring the file to a usable format in order to create nodes, alignments, or other useful data to facilitate surveying and staking.

The City of Madison shall provide initial local horizontal control (coordinates) and initial vertical control (benchmarks) for use during construction. The City will provide staking for all storm and sanitary sewer pipe and structures. The City will verify the bottom, safety shelf and top of pond or basin segments during construction. Contractor shall coordinate verification of the basin layout and elevations with the City. If it is found during verification that the grading is not set to the correct limits or elevation the contractor shall continue grading until the correct elevations are met at no additional cost to the City.

The Contractor shall use the established horizontal and vertical control points as provided by the City of Madison as initial control. The contractor may need to set additional control for completion of the project. Additional control set by the contractor shall be incidental to this bid item. It is the contractor's responsibility to check for accuracy of set control.

The City of Madison will check the accuracy of the detention basin grading in order to provide quality control. The City of Madison will also provide staking for storm pipe and structures. The Contractor shall contact the City

surveyor assigned to this project at least 48 hours prior to requesting storm sewer staking, elevation checks of subgrades and finished grades.

B. METHOD OF MEASUREMENT

Construction Surveying shall be measured as a Lump Sum for all construction surveying necessary for project completion throughout construction.

C. BASIS OF PAYMENT

Construction Surveying shall be paid for at the contract unit price, which shall be full compensation for all work, materials and incidental to complete the work described above.

PROPOSAL:

A summary of the changes to the proposal is as follows:

ACTION	ITEM NUMBER	TYPE OF WORK	UNITS
ADD	90019	CONSTRUCTION SURVEYING	LUMP SUM

Please see Bid Express for revised bid item quantities.

Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on the Bid Express web site at: <http://www.bidexpress.com>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

Sincerely,

Greg Fries for _____
Jim Wolfe, P.E., City Engineer

JMW: maa