



Office of City Engineering
City Engineering
Room 115, City County Building
210 Martin Luther King Jr. Boulevard
Madison, WI 53703-3346
TEL: 608/266-4751 FAX: 608/264-9275
Website: www.cityofmadison.com/engineering.html

ADDENDUM NO. 1
City of Madison, Engineering Department

CONTRACT NO. 9329
Fire Station 14 Training Site Phase 1

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

Acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on the Bid Express web site at:

<http://www.bidexpress.com>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

1. GENERAL CONTRACT CONDITIONS

Update City of Madison Construction Manager Contact as follows

Steve White
(608) 266-5969
(608) 574-7795
swhite@cityofmadison.com

2. GENERAL QUESTIONS AND ANSWERS

(a) Striping and Pavement Markings

1. The striping and pavement markings are not a part of the Bid Proposal. The cost of this is incidental to the project.

(b) Test Pit Results

2. Four test pits were conducted as part of the infiltration analysis for the site. They have been added to the bid documents as a Reference file.

(c) Future Training Tower Area

3. This is shown on the plans for reference only, no work from the Contractor is expected for this area.

3. SPECIFICATIONS

(a) Section 301.10 Concrete Waste Management

1. Strike all language under this section and replace with:

The Contractor shall use an earthen concrete washout for concrete management as shown on detail 2 on Sheet C401 of the project plans.

The Contractor shall review the entire Concrete Waste Management section of the City of Madison Standard Specifications for Public Works contracts for more information.

4. DRAWINGS

(a) Sheet C300

1. The concrete pavement thickness has been changed from 6” to 8” for the car training area. See keynote #5.

5. PROPOSAL

(b) Proposal Page

1. The following items are either added or modified from the existing Proposal Page
 - a. Add Bid item 90011 – 12” HDPE Storm Sewer Pipe (incl. Endwall)
 - b. Modify Quantity for item 40401 – 8” Concrete Pavement
 - c. Modify Quantity for item 40102 – Crushed Aggregate Base Course, Gradation No 2 or No 3

For questions regarding this bid, contact:

Steve White
(608) 266-5969
(608) 574-7795
swhite@cityofmadison.com