



---

## Traffic Engineering Division

David C. Dryer, City Traffic Engineer

Madison Municipal Building  
215 Martin Luther King, Jr. Boulevard  
P.O. Box 2986  
Madison, Wisconsin 53701-2986  
PH 608/266-4761  
TTY 608/267-9623  
FAX 608/267-1158

September 8, 2005

TO: Plan Commission

FROM: David C. Dryer, P.E., City Traffic Engineer

SUBJECT: **13 Atlas Avenue – Conditional Use – Outdoor Eating Area**

The City Traffic Engineering Division has reviewed the subject development and has the following comments.

**MAJOR OR NON-STANDARD REVIEW COMMENTS** (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None
---------

### GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

2. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), , signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'.
3. The applicant should show the dimensions for existing parking stalls' items A, B, C, D, E, and F, according to Figures II "Medium and Large Vehicles" parking design standards in Section 10.08(6)(b) 2.
4. A "Stop" sign shall be installed at a height of seven (7) feet at all driveway approaches. All signs at the approaches shall be installed behind the property line. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
5. The Developer shall post a deposit or reimburse the City for all costs associated with any modifications to Street Lighting, Signing and Pavement Marking including labor and materials for both temporary and permanent installations.

6. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact John Leach, City Traffic Engineering at 267-8755 if you have questions regarding the above items:

Contact Person: Gary Fox

Fax: 608-276-4468

Email:

DCD:DJM:dm