

Synthetic Organic Compound	Maximum Amount	MCL	Units	EPA Method	Well 15
					2/8
1,2-Dibromoethane (EDB)	Not Detected	0.05	ppb	504.1	<0.0041
1,2-Dibromo-3-Chloropropane (DBCP)	Not Detected	0.2	ppb	504.1	<0.0047
Chlordane	Not Detected	2	ppb	505	<0.033
PCB Total	Not Detected	0.5	ppb	505	<0.10
Toxaphene	Not Detected	3	ppb	505	<0.33
2,4-D	Not Detected	70	ppb	515.3	<0.058
Dalapon	Not Detected	200	ppb	515.3	<0.70
Dicamba	Not Detected	--	ppb	515.3	<0.23
Dinoseb	Not Detected	7	ppb	515.3	<0.14
Pentachlorophenol	Not Detected	1	ppb	515.3	<0.022
Picloram	Not Detected	500	ppb	515.3	<0.072
2,4,5-TP (Silvex)	Not Detected	50	ppb	515.3	<0.16
Alachlor	Not Detected	2	ppb	525.2	<0.029
Aldrin	Not Detected	--	ppb	525.2	<0.047
Atrazine	Not Detected	3	ppb	525.2	<0.060
Butachlor	Not Detected	--	ppb	525.2	<0.032
Dieldrin	Not Detected	--	ppb	525.2	<0.067
Endrin	Not Detected	2	ppb	525.2	<0.010
Heptachlor	Not Detected	0.4	ppb	525.2	<0.014
Heptachlor epoxide	Not Detected	0.2	ppb	525.2	<0.020
Hexachlorobenzene	Not Detected	1	ppb	525.2	<0.038
Hexachlorocyclopentadiene	Not Detected	50	ppb	525.2	<0.027
Lindane (BHC Gamma)	Not Detected	0.2	ppb	525.2	<0.020
Methoxychlor	Not Detected	40	ppb	525.2	<0.029
Metolachlor	Not Detected	--	ppb	525.2	<0.029
Metribuzin	Not Detected	--	ppb	525.2	<0.067
Propachlor	Not Detected	--	ppb	525.2	<0.036
Simazine	Not Detected	4	ppb	525.2	<0.067
Aldicarb	Not Detected	3	ppb	531.1	<0.35
Aldicarb sulfone	Not Detected	2	ppb	531.1	<0.34
Aldicarb sulfoxide	Not Detected	4	ppb	531.1	<0.32
Carbaryl	Not Detected	--	ppb	531.1	<0.34
Carbofuran	Not Detected	40	ppb	531.1	<0.38
3-Hydroxycarbofuran	Not Detected	--	ppb	531.1	<0.39
Methomyl	Not Detected	--	ppb	531.1	<0.36
Oxamyl	Not Detected	200	ppb	531.1	<0.32
Glyphosate	Not Detected	700	ppb	547	<4.7
Endothall	Not Detected	100	ppb	548.1	<0.51
Diquat	Not Detected	20	ppb	549	<0.32